

Hi Harry,

Thank you for your email which was sent to the National Grid Engineer assessing this enquiry. Please see the Engineer's response below.

'We would like further information regarding the proposed Solar Farm, if possible. What is the cable transmitting? AC or DC? This particular pipeline has AC Mitigation installed which is susceptible to picking up additional current. What are the proposed access points to the construction area and the types of vehicles to be used/how often these will pass over the pipe? The easement on this section of pipe is a total of 24.4m. We will require a Deed of Consent for the cable to pass over the pipeline, which will also require NG supervision for trial holing and installation. We would also require an Earthing Report prior to any cabling being installed. I have attached UKOPA Guidance and SSW22 with regards to working in the vicinity of the Gas Pipeline. Please do let me know if you need further information from me.'

Please could you provide a response to the Engineer's comment in order to progress this enquiry.

Kind regards

Jasmine Surana

Asset Protection Assistant
Compliance and Integrity
Gas Transmission
Engineering and Asset Management

[nationalgrid](#)

Email:

Tel: 0

National Grid House, (Floor B2), Warwick Technology Park, Gallows Hill, Warwick, CV34 6DA

[nationalgrid.com](#) | [Twitter](#) | [LinkedIn](#)